"Progress Through Innovation, Technology and Customer Satisfaction"



February 8, 2006

AKRON RUBBER DEVELOPMENT LABORATORY, INC. 2887 Gilchrist Road • Akron, Ohio 44305 1-800-830-ARDL • (330) 794-6600 • FAX (330) 794-6610 Website: www.ardl.com • E-mail: info@ardl.com

- TEST REPORT -

PN# 66025 PO#

Prepared for:

Shamini Shanmugam GB Industries Sdn. Bhd. 44-1 Jalan USJ 10/1b 47620 Subang Jaya Selangor Malaysia

Prepared by:

Sandy Johes

Approved by:

im Drummond



AN A2LA ACCREDITED LABORATORY
MEMBER OF ACIL: THE ASSOCIATION OF INDEPENDENT SCIENTIFIC,
ENGINEERING AND TESTING FIRMS

ISO 9001 Registered

MEMBER

"Progress Through Innovation, Technology and Customer Satisfaction"



Page 1 of 3- PN# 66025

February 8, 2006

Shamini Shanmugam GB Industries Sdn. Bhd. 44-1 Jalan USJ 10/1b 47620 Subang Jaya Selangor Malaysia AKRON RUBBER DEVELOPMENT LABORATORY, INC. 2887 Gilchrist Road • Akron, Ohio 44305 1-800-830-ARDL • (330) 794-6600 • FAX (330) 794-661 Website: www.ardl.com • E-mail: info@ardl.com

SUBJECT:

Physical testing on material submitted by the above company to ASTM D 120-02a test specification.

PO# Wire Transfer

RECEIVED:

Two (2) pairs of gloves identified as Novax Orange Rubber Insulating Gloves Class 1 Beaded Cuff

Size 8

POLYMER IDENTIFICATION, ASTM D 3677-90(95)

Instrument:

Perkin-Elmer Spectrum BX Spectrometer

Resolution:

4.0

Number of Scans:

6.

Method of Preparation: Film

RESULTS

Polyisoprene

DIMENSIONS, PARA. 17.1 - 17.3.1

Three gloves tested.

Average of four readings reported.

REQUIREMENTS:

Thickness Crotch, mm = 0.63 - 1.52

Thickness Palm & Back, mm = 0.76 - 1.52

	LENGTH, mm	WIDTH, mm	PALM, mm	CROTCH, mm	BACK, mm
Glove 1	355	190	1.30	1.21	1.38
Glove 2	357	186	1.34	1.20	1.34
Glove 3	358	192	1.31	1.24	1.35

ORIGINAL PHYSICAL PROPERTIES, ASTM D 412-98a(02)e1, D 2240-03, D 624-00e1

Die C dumbbells tested at 20 in/min.

	<u>RESULTS</u>	REQUIREMENTS	PASS/FAIL
Shore A Durometer, points Tensile Strength, MPa Ultimate Elongation, % 100% Modulus, MPa 200% Modulus, MPa 300% Modulus, MPa Tear Strength Die C, kN/m	39 27.9 824 0.75 1.04 1.41 51.4	47 max. 17.2 min. 600 min. 2.1 max.	Pass Pass Pass

Page 2 of 3- PN# 66025

February 8, 2006

Shamini Shanmugam GB Industries Sdn. Bhd.

PUNCTURE RESISTANCE, ASTM D 120-02a

Palm area punctured at 20 in/min.

	<u>RESULTS</u>	<u>REQUIREMENTS</u>	PASS/FAIL
Puncture Resistance, kN/m	19.32	18 min.	Pass

OZONE RESISTANCE, ASTM D 1149-99

Test specimens per ASTM D 518-99, Method A Specimens exposed 3 hrs. @ 50 pphm @ 40°C, 20% elongation. Observations made at 7x magnification.

RESULTS	REQUIREMENTS	PASS/FAIL
No cracks	No cracks	Pass

HEAT-AGED PROPERTIES, ASTM D 573-04

Specimens aged 168 hrs. @ 70°C in a forced air oven.

	<u>RESULTS</u>	REQUIREMENTS	PASS/FAIL
Durometer, point change	-6	•	-
Tensile Strength, % of original	96.4	80 min	Pass
Elongation, % of original	99.7	80 min.	Pass

A-C PROOF TEST ASTM D120-95, SECTION 18.4.2

The glove was filled with tap water and immersed in water to a depth about 1 ½ inches from the cuff. A metal rod was lowered inside the glove as one electrode and a metal rod placed in the water tank outside the glove as the other electrode. A voltage was applied to the electrodes at an increasing rate of 1,000 V/s until specified voltage was reached. For Class 1 glove a maximum voltage of 10,000 V and a maximum current of 14 mA were used. The voltage was applied for a period of 3 minutes after which the voltage was lowered to 0 V.

		Pass/Fail		Measured	d Current
1 2-	원1 :	Passed Passed		6 mA 6 mA -	2.1

Page 3 of 3 - PN# 66025

February 8, 2006

Shamini Shanmugam GB Industries Sdn. Bhd.

A-C MOISTURE ABSORPTION/PROOF TEST ASTM D120-95, SECTION 18.4.4

The glove was filled with tap water and immersed in water to a depth about 1 ½ inches from the cuff. The glove was soaked for a period of 16 hours. A metal rod was lowered inside the glove as one electrode and a metal rod placed in the water tank outside the glove as the other electrode. A voltage was applied to the electrodes at an increasing rate of 1,000 V/s until specified voltage was reached. For Class 1 glove a maximum voltage of 10,000 V and a maximum current of 14 mA were used. The specified voltage was applied for a period of 3 minutes after which the voltage was lowered to 0 V.

	<u>Pass/Fail</u>	Measured Current
1	Passed	10 mA
2	Passed	10 mA

A-C BREAKDOWN TEST ASTM D120-95, SECTION 18.4.3

The glove was filled with tap water and immersed in water to a depth about 1 ½ inches from the cuff. A metal rod was lowered inside the glove as one electrode and a metal rod placed in the water tank outside the glove as the other electrode. A voltage was applied to the electrodes at an increasing rate of 1,000 V/s until specified voltage was reached. For Class 1 glove a maximum voltage of 20,000 V was used.

	Pass/Fail		Measured Current
1	Passed	¥-	26 mA
2	Passed		28 mA

Sandy Jones

Project Technician

AKRON RUBBER DEVELOPMENT LABORATORY, INC

PN# 66025 SJ/JD/sc Jim Drummond

Physical Testing Manager