"Progress Through Innovation, Technology and Customer Satisfaction"



June 8, 2006

AKRON RUBBER DEVELOPMENT LABORATORY, INC. 2887 Gilchrist Road • Akron, Ohio 44305 1-800-830-ARDL • (330) 794-6600 • FAX (330) 794-661 Website: www.ardl.com • E-mail: info@ardl.com

- TEST REPORT -

P/N 67230B PO#

Prepared for:

GB Industries Sdn. Bhd. 22-2 Jalan USJ 21/7 47630 Subang Jaya Selangor Malaysia

Prepared by

3and√⊿ones

Approved by:

lim Drummond

AN A2LA ACCREDITED LABORATORY
MEMBER OF ACIL: THE ASSOCIATION OF INDEPENDENT SCIENTIFIC,
ENGINEERING AND TESTING FIRMS

ISO 9001 Registered





"Progress Through Innovation, Technology and Customer Satisfaction"



Page 1 of 3- PN# 67230B

June 8, 2006

AKRON RUBBER DEVELOPMENT LABORATORY, INC. 2887 Gilchrist Road • Akron, Ohio 44305 1-800-830-ARDL • (330) 794-6600 • FAX (330) 794-661 Website: www.ardl.com • E-mail: info@ardl.com

GB Industries Sdn. Bhd. 22-2 Jalan USJ 21/7 47630 Subang Jaya Selangor Malaysia

SUBJECT:

Various Property Testing per ASTM D120 on Novax Gloves

PO#

RECEIVED:

Three Pairs of Gloves identified as Novax Rubber Insulating Gloves (Class 2).

POLYMER IDENTIFICATION, ASTM 3677-00

Instrument:

Perkin-Elmer Spectrum BX Spectrometer

Resolution:

4.0

Number of Scans:

6

Method of Preparation:

Film

RESULTS

Polyisoprene

DIMENSIONS, PARA. 17.1 - 17.3.1

Three gloves tested.

Average of four readings reported.

REQUIREMENTS:

Thickness Crotch, mm = 1.02 - 2.29

Thickness Palm & Back, mm = 1.27-2.29

	LENGTH, mm	WIDTH, mm	PALM, mm	CROTCH, mm	BACK, mm
Glove 1	355	232	2.23	2.09	2.17
Glove 2	356	256	2.24	1.99	2.18
Glove 3	355	274	2.06	1.97	2.06

ORIGINAL PHYSICAL PROPERTIES, ASTM D 412-98a(02)e1, D 2240-03, D 624-00e1

Die C dumbbells tested at 20 in/min.

	<u>RESULTS</u>	REQUIREMENTS	PASS/FAIL
Shore A Durometer, points Tensile Strength, MPa Ultimate Elongation, %	36	47 max. 17.2 min. 600 min.	Pass Pass Pass
100% Modulus, MPa	. 0.801	·**	
200% Modulus, MPa	1.172	2.1 max.	Pass
300% Modulus, MPa	1.687	_	~
Tear Strength Die C, kN/m	49.1	. 21 min.	Pass

Page 2 of 3- PN# 67230B

June 8, 2006

GB Industries Sdn. Bhd.

PUNCTURE RESISTANCE, ASTM D 120-02a

Palm area punctured at 20 in/min.

Puncture Resistance, kN/m

RESULTS REQUIREMENTS PASS/FAIL

162 18 min. Pass

OZONE RESISTANCE, ASTM D 1149-99

Test specimens per ASTM D 518-99, Method A Specimens exposed 3 hrs. @ 50 pphm @ 40°C, 20% elongation. Observations made at 7x magnification.

RESULTS REQUIREMENTS PASS/FAIL

No cracks No cracks Pass

HEAT-AGED PROPERTIES, ASTM D 573-04

Specimens aged 168 hrs. @ 70°C in a forced air oven.

	RESULTS	REQUIREMENTS	PASS/FAIL
Durometer, point change	0	<u></u>	<u></u>
Tensile Strength, % of original	103.6	80 min	Pass
Elongation, % of original	98.7	80 min.	Pass

A-C PROOF TEST, ASTM D 120-95 SECTION 18.4.2

The glove was filled with tap water and immersed in water to a depth about $2 \frac{1}{2}$ inches from the cuff. A metal rod was lowered inside the glove as one electrode and a metal rod placed in the water tank outside the glove as the other electrode. A voltage was applied to the electrodes at an increasing rate of 1,000 V/s until specified voltage was reached. For Class 2 glove a maximum voltage of 20,000 V and a maximum current of 16 mA were used. The voltage was applied for a period of 3 minutes after which the voltage was lowered to 0 V.

2.	Pass/Fail	Measured Current
Class 2	• •	
Glove 1	Passed	5 mA 🔝
Glove 2	Passed	5 mA
Glove 3	Passed	4 mA

Page 3 of 3- PN# 67230B

June 8, 2006

GB Industries Sdn. Bhd.

A-C MOISTURE ABSORPTION/PROOF TEST, ASTM D 120-95 SECTION 18.4.4

The glove was filled with tap water and immersed in water to a depth about 2 ½ inches from the cuff. The glove was soaked for a period of 16 hours. A metal rod was lowered inside the glove as one electrode and a metal rod placed in the water tank outside the glove as the other electrode. A voltage was applied to the electrodes at an increasing rate of 1,000 V/s until specified voltage was reached. For Class 2 glove a maximum voltage of 20,000 V and a maximum current of 16 mA were used. The specified voltage was applied for a period of 3 minutes after which the voltage was lowered to 0 V.

Class 2	Pass/Fail	Measured Current
Glove 1	Passed	8 mA
Glove 2	Passed	8 mA
Glove 3	Passed	7 mA

A-C BREAKDOWN TEST, ASTM D 120-95 SECTION 18.4.3

The glove was filled with tap water and immersed in water to a depth about 3 inches from the cuff. A metal rod was lowered inside the glove as one electrode and a metal rod placed in the water tank outside the glove as the other electrode. A voltage was applied to the electrodes at an increasing rate of 1,000 V/s until specified voltage was reached. For Class 2 glove a maximum voltage of 30,000 V was used.

Class 2	Breakdown Voltage (VAC)	Pass/Fail	Measured Current at 30 kV
Glove 1	N/A	Pass	12 mA
Glove 2 Glove 3	N/A N/A	Pass Pass	11 mA 12 mA

Sandy Jones

Project Technician

AKRON RUBBER DEVELOPMENT LABORATORY, INC.

PN# 67230B SJ/JD/ks Jim Drummand

Physical Testing Manager