

July 30, 2008

· TEST REPORT ·

PN 79936C

PO

Physical Testing Department

Prepared For:

Shamini Shanmugam GB Industries Sdn. Bhd. No. 61-1 Jalan 9/5S 47630 Subang Jaya Selangor Darul Ehsan Malaysia

Prepared By:

A Testing Lab

Sandy Jones Project Technician Approxed By:

Jim Drummond
Physical Testing, Manager

An A2LA Accredited Testing Laboratory — Certificate Numbers 255.01 & 255.02 ISQ 9001:2000 Registered

Member of ACIL: The American Council of Independent Laboratories

ISO 9001:2000

Registered



Letters and reports are for the exclusive use of the clients to whom they are addressed and shall not be reproduced, except in full, without the written permission of Akron Rubber Development Laboratory, Inc. (ARDL). The Information contained herein applies to the permission of Akron Rubber Development Laboratory, Inc. (ARDL). The Information contained herein applies to the permission paid for services. ARDL Inc. is accredited by AZIA for the test methods listed on the attached scope.

286 Jilchrist Rd. | Akron, Onio 44305 | answers@ardl.com.

Toll Free (800) 830-ARDL | Worldwide (330) 794-6600 | Fax (330) 794-6610



Testing. Development. Problem Solving.

July 30, 3008

Shamini Shanmugam GB Industries Sdn. Bhd.

Page 2 of 4 PN 79936C

SUBJECT:

Physical testing on material submitted by the above company ASTM D 120 Class 4 test specification.

PO#

RECEIVED:

Six (6) pairs of Novax Rubber Insulting gloves identified as Orange Class 4.

DIMENSIONS, PARA. 17.1 - 17.3.1

Three gloves tested.

Average of four readings reported.

REQUIREMENTS:

Thickness Crotch, mm = 2.03 - 2.56

Thickness Palm & Back, mm = 2.54-3.56

	LENGTH, mm	WIDTH, mm	PALM, mm	CROTCH, mm	BACK, mm
Glove 1	455	136	3.48	3.47	3.53
Glove 2	450	130	3.52	3.66	3.49
Glove 3	453	140	3.53	3.70	3.41

ORIGINAL PHYSICAL PROPERTIES, ASTM D 412-06, D 2240-05, D 624-00e1

Die C dumbbells tested at 20 in/min.

	<u>RESULTS</u>	REQUIREMENTS	PASS/FAIL
Shore A Durometer, points Tensile Strength, MPa Ultimate Elongation, % 200% Modulus, MPa Tension Set @ 400%, %	38	47 max.	Pass
	26.8	17.2 min.	Pass
	692	600 min.	Pass
	1.034	2.1 max.	Pass
	5.5	25 max.	Pass

TEAR RESISTANCE, ASTM D 624-00e1, DIE C

Specimens tested at 20 in/min.

Tear Strength, kN/m

<u>RESULTS</u>	REQUIREMENTS	PASS/FAIL
36.9	21 min.	Pass

ARDL is accredited by AZLA for the test methods listed on the attached scope 2887 Gilchrist Rd. | Akron, Ohio 44305 | answers@ardl.com
Toll Free (800) 830-ARDL | Worldwide (330) 794-6600 | Fax (330) 794-6610

July 30, 3008

Shamini Shanmugam GB Industries Sdn. Bhd.

Page 3 of 4 PN 79936C

PUNCTURE RESISTANCE, ASTM D 120-02a

Palm area punctured at 20 in/min.

RESULTS REQUIREMENTS PASS/FAIL

Puncture Resistance, kN/m 24.0 18 min. Pass

OZONE RESISTANCE, ASTM D 1149-99

Test specimens per ASTM D 518-99, Method A Specimens exposed 3 hrs. @ 50 pphm @ 40°C, 20% elongation. Observations made at 7x magnification.

RESULTS REQUIREMENTS PASS/FAIL

No cracks No cracks Pass

HEAT-AGED PROPERTIES, ASTM D 573-04

Specimens aged 168 hrs. @ 70°C in a forced air oven.

RESULTSREQUIREMENTSPASS/FAILDurometer, point change-2-Tensile Strength, % of original106.180 minPassElongation, % of original98.880 minPass

POLYMER IDENTIFICATION, ASTM D 3677-00(04)

Instrument: Perkin-Elmer Autoimage FT-IR Microscope

Number of Scans: 32 Method of Preparation: Film

RESULTS

Polyisoprene

A-C PROOF TEST, ASDTM D 120-02a SECTION 18.4.2

The glove was filled with tap water and immersed in water to a depth about 5 inches from the cuff. A metal rod was lowered inside the glove as one electrode and a metal rod placed in the water tank outside the glove as the other electrode. A voltage was applied to the electrodes at an increasing rate of 1000 V/s until specified voltage for each class of glove was reached. For Class 4 gloves a maximum voltage of 40,000 V and a maximum current of 24 mA were used. The specified voltage was applied for a period of 3 minutes after which the voltage was lowered to 0 V.

Sample Pass/Fail Measured Current

Orange Passed 14 mA

July 30, 3008

Shamini Shanmugam GB Industries Sdn. Bhd. Page 4 of 4 PN 79936C

A-C MOISTURE ABSORPTION/PROOF TEST, ASTM D 120-02a SECTION 18.4.4

The glove was filled with tap water and immersed in water to a depth about 5 inches from the cuff. The glove was soaked for a period of 16 hours. A metal rod was lowered inside the glove as one electrode and a metal rod placed in the water tank outside the glove as the other electrode. A voltage was applied to the electrodes at an increasing rate of 1000 V/s until specified voltage for each class of glove was reached. For Class 4 gloves a maximum voltage of 40,000 V and a maximum current of 24 mA were used. The specified voltage was applied for a period of 3 minutes after which the voltage was lowered to 0 V.

Sample

Pass/Fail

Measured Current

Orange

Passed

15 mA

A-C BREAKDOWN TEST, ASTM D 120-95 SECTION 18.4.3

The glove was filled with tap water and immersed in water to a depth about 6 ½ inches from the cuff. A metal rod was lowered inside the glove as one electrode and a metal rod placed in the water tank outside the glove as the other electrode. A voltage was applied to the electrodes at an increasing rate of 1000 V/s until specified voltage for each class of glove was reached. For Class 4 gloves a maximum voltage of 50,000 V was used.

Sample

Pass/Fail

Voltage Applied (VAC)

Orange

Passed

50.000*

NOTE: Flashover-arcing occurred with both samples, however, no breakdown was observed.

Prepared By:

Sandy/Jøne

Project Technician

Approved By:

Jim Drummond

Physical Testing, Manager

*ARDL is accredited by A2LA for the test methods listed on the attached scope