

Sponsor: Kee Wei Wong Safetyware Sdn. Bhd. Plot 237, Lengkok Perindustrian Bukit Minyak 3 Bukit Minyak Industrial Estate Simpang Ampat, Pulau Pinang, 14100 MALAYSIA

Differential Pressure (Delta P) Final Report

Test Article: 1302

Study Number: 1318168-S01 Study Received Date: 08 Jul 2020

Testing Facility: Nelson Laboratories, LLC

6280 S. Redwood Rd.

Salt Lake City, UT 84123 U.S.A.

Test Procedure(s): Standard Test Protocol (STP) Number: STP0004 Rev 18

Deviation(s): None

Summary: The Delta P test is performed to determine the breathability of test articles by measuring the differential air pressure on either side of the test article using a manometer, at a constant flow rate. The Delta P test complies with EN 14683:2019, Annex C and ASTM F2100-19.

All test method acceptance criteria were met. Testing was performed in compliance with US FDA good manufacturing practice (GMP) regulations 21 CFR Parts 210, 211 and 820.

Test Side: Inside

Delta P Flow Rate: 8 Liters per minute (L/min)

Conditioning Parameters: 85 ± 5% relative humidity (RH) and 21 ± 5°C for a minimum of 4 hours

Test Article Dimensions: ~174 mm x ~168 mm

Results:

Test Article Number	Delta P (mm H ₂ O/cm ²)	Delta P (Pa/cm²)
1	5.1	50.4
2	4.9	47.6
3	5.2	51.1
4	5.7	55.4
5	5.5	53.8





McKenna Wild electronically approved for

James Luskin

29 Jul 2020 17:23 (+00:00)

Study Director

Study Completion Date and Time

801-290-7500

nelsonlabs.com

sales@nelsonlabs.com

FRT0004-0001 Rev 22 Page 1 of 1